



## Room Temperature Sensors

**QAA24/AP**  
**QAA25/AP**

- Landis & Staefa Ni 1000 sensing element
- Units with (QAA25/AP) and without (QAA24/AP) setpoint adjuster

### Use

In HVAC plants to acquire and adjust the room temperature, especially where a high level of comfort is required.

Suitable for all systems and units that are capable of handling Landis & Staefa Ni 1000 signals, such as POLIGYR® RCM6..., RCE6..., RWF..., RWX62... and RWC...

### Functions

The sensor acquires the room temperature by means of its Landis & Staefa Ni 1000 sensing element. The resistance value changes according to the ambient temperature.

### Type summary

Type reference	Description
<b>QAA24/AP</b>	Room temperature sensor
<b>QAA25/AP</b>	Room temperature sensor with setpoint adjuster from 5 to 35 °C
<b>ARG70</b>	Adapter plate 120 x 120 mm for 4" x 4" conduit boxes
<b>ARG70.1</b>	Adapter plate 96 x 120 mm for 2" x 4" conduit boxes

### Mechanical design

The units have been designed for wall mounting. They are suitable for use with most commercially available recessed conduit boxes. The cables can be introduced from the rear (concealed wiring).


## Installation notes

Location	On a flat inner wall of the space to be heated or air conditioned. Not in recesses, shelves, not behind curtains, not opposite or near heat sources. The unit must not be exposed to direct solar radiation.
Notes	<ul style="list-style-type: none"> <li>• When installing the unit, fix the baseplate first, then hook on the body and make the electrical connections. Then fit the cover and secure it.</li> <li>• The end of the conduit at the sensor must be sealed to prevent false measurements due to draughts through the conduit.</li> <li>• The permissible environmental conditions should be observed.</li> <li>• Installation instructions are printed on the packing.</li> </ul>


## Technical data

General unit data	Operating range	0...50 °C
	Setting rang for QAA25/AP	5...35 °C
	Temperature setpoint: 5 °C	corresponding resistance: 100 Ω
	35 °C	660 Ω
	Sensing element	Landis & Staefa Ni 1000 (1000 Ω at 0 °C)
	Maximum voltage	AC 24 V
	Time constant (with air movement)	
	QAA24/AP	approx. 2 min
	QAA25/AP	approx. 4 min
Connection	Terminals for cross-sectional areas of	2 x 1.5 mm <sup>2</sup> or 1 x 2.5 mm <sup>2</sup>
Environmental conditions	Operation	to IEC 721-3-3
	Climatic conditions Temperature Humidity Pollution degree	class 3K5 0...50 °C <85 % r. h. normal, to EN 60730
	Transport	to IEC 721-3-2
	Climatic conditions Temperature Humidity	class 2K3 -25...+65 °C <95 % r. h.
Requirements	Mechanical conditions	class 2M2
	Safety class	III to EN 60 730
	Degree of protection	IP 30 to EN 60 529
	CE conformity	to EMC directive 89/336/EEC
Miscellaneous	Weight	approx. 0.1 kg
	Colour	white, NCS S 0502-G (RAL 9003)

## Internal diagram



QAA24/AP



QAA25/AP

B1 Room temperature signal  
 B2 Setpoint signal  
 M Measuring neutral

## Dimensions

### Unit and Baseplate

